


	GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT RENEWAL of NO OBJECTION CERTIFICATE														
Ack. No.	12052002018														
NOC	0001452/RENEWAL/HYD/2019														
NOC TYPE	RENEWAL*														
Valid Upto	04-10-2023														
Applicant Details	T V R Murthy														
Building for which NOC issued	Howard Public School, D No 3-6-567&567/1&568 Himayat Nagar, Hyderabad														
Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening		No													
Plot Area (Sq Mtrs)	2328.00	Height (Metres)	12.60												
Open Spaces (Metres)	North: 2.00	South: 5.50	East: 2.00 West: 8.79												
		Occupancy Type	EDUCATIONAL B-I Schools up to senior secondary level												
Total Built-up Area (Sq Mtrs)	2863.00	Staircases:	No. of Staircases Required/Proposed: 2												
Fees Paid (₹)	44500		Aggregate Width Required/Proposed (Metres): 1.50												
Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:															
Fire Extinguisher	20	First Aid Hose Reel	4 Wet Riser 0												
Down Comer	1	Yard Hydrant	0 Automatic Sprinkler System 0												
Manually Operated Electronic Fire Alarm Systems	0	Terrace Tank (Litres)	20000												
Automatic Detection and Alarm System	0	Underground Static Water Storage Tank (Litres)	20000												
Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Terrace Level	<table border="1"> <thead> <tr> <th>Type</th> <th>Quantity</th> <th>(Capacity in Litres/min)</th> </tr> </thead> <tbody> <tr> <td>Electrical</td> <td>0</td> <td>0</td> </tr> <tr> <td>Diesel</td> <td>0</td> <td>0</td> </tr> <tr> <td>Jockey</td> <td>0</td> <td>0</td> </tr> </tbody> </table>			Type	Quantity	(Capacity in Litres/min)	Electrical	0	0	Diesel	0	0	Jockey	0	0
Type	Quantity	(Capacity in Litres/min)													
Electrical	0	0													
Diesel	0	0													
Jockey	0	0													
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm ²	<table border="1"> <thead> <tr> <th>(Capacity in Litres/min)</th> </tr> </thead> <tbody> <tr> <td>900</td> </tr> </tbody> </table>			(Capacity in Litres/min)	900										
(Capacity in Litres/min)															
900															
THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE*															
* For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf															


Secretary / Correspondent
HOWARD PUBLIC SCHOOL
HYDERABAD-500 029


PRINCIPAL
HOWARD PUBLIC SCHOOL
HYDERABAD-500 029




GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT NO
OBJECTION CERTIFICATE



The Renewal No Objection Certificate for Occupancy is issued subject to following conditions

- On the basis of the recommendations of the building inspection committee, this Renewal No Objection Certificate for Occupancy is issued.
 - Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
 - The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
 - It is the responsibility of the builder/management to apply for Renewal No Objection Certificate for Occupancy duly remitting the user charges as per G.O. Ms No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.
- f) The floor wise built-up areas of the building are as follows:

Floor Type	Build Up Area
Ground	536.71
1st Floor	661.50
2nd Floor	661.50
3rd Floor	468.36
Total	2328.07


Secretary / Correspondent
HOWARD PUBLIC SCHOOL,
HYDERABAD-500 029


PRINCIPAL
HOWARD PUBLIC SCHOOL
HYDERABAD-500 029